

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

wenglor sensoric gmbh

wenglor Straße 3, 88069 Tettngang, Germany

the Certificate No: **Z10687** for the PROFINET IO Device:

Model Name: EPGG001
Revision: SW/FW: V2.4.3; HW: 2
Identnumber: 0x01D3; 0x0401
GSD: GSDML-V2.3-wenglor-wenglor gateway-20131010.xml
DAP: DAP 2P 1, 0xA0000000

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

<input checked="" type="checkbox"/> Hardware	Auto_Negotiation, Auto_Polarity, Auto_Crossover
<input checked="" type="checkbox"/> Conformance Class B	RT_CLASS_1, RTA, LLDP

Test Report Number: PN-AIT-14-03
Authorized Test Laboratory: AIT, Gummersbach, Germany

The tests were executed in accordance with the following documents:
"Test Specifications for PROFINET IO devices, Version 2.2.4 from December 2010" and
"Test Cases for PN-Tester for PROFINET IO devices, Version 2.2.4.16.21".

This certificate is granted according to the document:
"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **January 17, 2029** the certificate is valid for life.

Karlsruhe, April 08, 2026

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)

(Xaver Schmidt)



(Frank Moritz)