ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

C E R T I F I C A T E

No. Z10 040594 0040 Rev. 00

Holder of Certificate: **wenglor sensoric GmbH**
wenglor Str. 3
88069 Tettnang
GERMANY

Certification Mark:

Product: **Safety components**
Control units

Model(s): **SS2-00VA000R4**

Parameters:

Power Supply (Relay):	24VDC ±20%
Degree of Protection:	IP20
Max Output (Relay):	250 Vac or 125 Vdc, 6 A max.

Tested according to:

EN 61508-1:2010 (SIL 1)
EN 61508-2:2010 (SIL 1)
EN 61508-3:2010 (SIL 1)
EN 62061:2005/A2:2015 (SILCL 1)
EN ISO 13849-1:2015 (Cat 2, PL c)
EN IEC 61496-1:2020 (Type 2)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: WT104736T

Valid until: 2026-05-03

Date, 2025-05-06

(Peter Weiß)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®