

RTE Config J1xx



Description of Configuration File

Basics

- Device Type: MVC
- Number of Processing Instances: xx (coded in the name of the configuration file, e.g. J101 is for 1 Processing Instances)
- Protocol: EtherCAT

Input and Output Size

Configuration File	Input Bytes	Output Bytes
J101	144	36

Configuration

- Inputs (Device to PLC)
 - 8 Bytes Input: Device Status
 - For each Processing Instance
 - 8 Bytes Input: Status of Processing Instance
 - 128 Bytes Input: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 124 Bytes: 31 REAL
- Outputs (PLC to Device)
 - For each Processing Instance
 - 4 Bytes Output: Commands
 - 32 Bytes Output: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 28 Bytes: 7 REAL



NOTE!

For common info (e.g. status and command bits) check the interface protocol.