

# RTE Config F201



## Description of Configuration File

# Basics

- Device Type: B60
- Protocol: EtherNet/IP

## Input and Output Size

| Input Bytes | Output Bytes |
|-------------|--------------|
| 128         | 40           |

## Configuration

- Inputs (Device to PLC)
  - » 8 Bytes Input: Device Status
  - » 8 Bytes Input: Status of Processing Instance
  - » 112 Bytes Input: User-Defined Process Data
    - 4 Bytes: 32 BOOL
    - 4 Bytes: 1 DINT
    - 8 Bytes: 2 REAL
    - 96 Bytes: 3 CHAR with 32 Bytes
- Outputs (PLC to Device)
  - » 4 Bytes Output: Commands
  - » 36 Bytes Output: User-Defined Process Data
    - 4 Bytes: 32 BOOL
    - 32 Bytes: 1 CHAR with 32 Bytes



**NOTE!**  
For common info (e.g. status and command bits) check the interface protocol.