

# RTE Config H001



## Description of Configuration File

## Basics

- Device Type: B60
- Protocol: PROFINET

## Slot Configuration

- 8 Bytes Input: Device Status
- 8 Bytes Input: Status of Processing Instance
- 64 Bytes Input: User-Defined Process Data
- 4 Bytes Output: Commands
- 64 Bytes Output: User-Defined Process Data

## User-Defined Process Data Input (Device to PLC)

- 4 Bytes: 32 BOOL
- 12 Bytes: 3 DINT
- 16 Bytes: 4 REAL
- 32 Bytes: 1 CHAR with 32 Bytes

## User-Defined Process Data Output (PLC to Device)

- 4 Bytes: 32 BOOL
- 12 Bytes: 3 DINT
- 16 Bytes: 4 REAL
- 32 Bytes: 1 CHAR with 32 Bytes



### NOTE!

For common info (e.g. status and command bits) check the interface protocol.