

RTE Config H101



Description of Configuration File

Basics

- Device Type: B60
- Protocol: PROFINET

Slot Configuration

- 8 Bytes Input: Device Status
- 8 Bytes Input: Status of Processing Instance
- 64 Bytes Input: User-Defined Process Data
- 64 Bytes Input: User-Defined Process Data
- 4 Bytes Output: Commands
- 32 Bytes Output: User-Defined Process Data

User-Defined Process Data Input (Device to PLC)

- 4 Bytes: 32 BOOL
- 60 Bytes: 15 REAL
- 64 Bytes: 16 REAL

User-Defined Process Data Output (PLC to Device)

- 4 Bytes: 32 BOOL
- 28 Bytes: 7 REAL



NOTE!

For common info (e.g. status and command bits) check the interface protocol.