

RTE Config I101



Description of Configuration File

Basics

- Device Type: B60
- Protocol: EtherCAT

Input and Output Size

Input Bytes	Output Bytes
144	36

Configuration

- Inputs (Device to PLC)
 - 8 Bytes Input: Device Status
 - 8 Bytes Input: Status of Processing Instance
 - 128 Bytes Input: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 124 Bytes: 31 REAL
- Outputs (PLC to Device)
 - 4 Bytes Output: Commands
 - 32 Bytes Output: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 28 Bytes: 7 REAL



NOTE!
For common info (e.g. status and command bits) check the interface protocol.