

RTE Config I201



Description of Configuration File

Basics

- Device Type: B60
- Protocol: EtherCAT

Input and Output Size

Input Bytes	Output Bytes
128	40

Configuration

- Inputs (Device to PLC)
 - 8 Bytes Input: Device Status
 - 8 Bytes Input: Status of Processing Instance
 - 112 Bytes Input: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 4 Bytes: 1 DINT
 - 8 Bytes: 2 REAL
 - 96 Bytes: 3 CHAR with 32 Bytes
- Outputs (PLC to Device)
 - 4 Bytes Output: Commands
 - 36 Bytes Output: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 32 Bytes: 1 CHAR with 32 Bytes



NOTE!
For common info (e.g. status and command bits) check the interface protocol.