

RTE Config I301



Description of Configuration File

Basics

- Device Type: B60
- Protocol: EtherCAT

Input and Output Size

Input Bytes	Output Bytes
96	72

Configuration

- Inputs (Device to PLC)
 - 8 Bytes Input: Device Status
 - 8 Bytes Input: Status of Processing Instance
 - 80 Bytes Input: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 4 Bytes: 1 DINT
 - 8 Bytes: 2 REAL
 - 64 Bytes: 1 CHAR with 64 Bytes
- Outputs (PLC to Device)
 - 4 Bytes Output: Commands
 - 68 Bytes Output: User-Defined Process Data
 - 4 Bytes: 32 BOOL
 - 64 Bytes: 1 CHAR with 64 Bytes



NOTE!
For common info (e.g. status and command bits) check the interface protocol.