EN

RTE Config E3xx



Description of Configuration File

Subject to change without notice
Available as PDF only
Status: 18.11.2025
www.wenglor.com

Basics

- Device Type: MVC
- Number of Processing Instances: xx (coded in the name of the configuration file, e.g. E302 is for 2 Processing Instances)
- Protocol: PROFINET

Slot Configuration

- 8 Bytes Input: Device Status
- Slots for each Processing Instance:
  - » 8 Bytes Input: Status of Processing Instance
  - » 16 Bytes Input: User-Defined Process Data
  - » 64 Bytes Input: User-Defined Process Data
  - » 4 Bytes Output: Commands
  - » 4 Bytes Output: User-Defined Process Data
  - » 64 Bytes Output: User-Defined Process Data

User-Defined Process Data Input (Device to PLC)

- 4 Bytes: 32 BOOL
- 4 Bytes: 1 DINT
- 8 Bytes: 2 REAL
- 64 Bytes: 1 STRING with 64 Bytes

User-Defined Process Data Output (PLC to Device)

- 4 Bytes: 32 BOOL
- 64 Bytes: 1 STRING with 64 Bytes



NOTE!
For common info (e.g. status and command bits) check the interface protocol.