

Information for Operating Instruction

Connection Diagrams for temperature sensors with two switching outputs



Operating structure for temperature sensors with two switching outputs



Edit Mode
- Changes digit value
- Changes selected digit position
- Quit Edit mode

- **oUt** Switching output 2 normally closed (n.c.)/ normally open (n.o.) Factory setting: normally open (n.o.)
- **SP** Switching point Factory setting: 50 % of measuring range + 10 K
- **Sou2** Menu level for switching output 2

- **oUt** Switching output 1 normally closed (n.c.)/ normally open (n.o.) Factory setting: normally open (n.o.)
- **SP** Switching point Factory setting: 50 % of measuring range
- **Sou1** Menu level for switching output 1

Display the applied temperature

Explanation of the Switching Status Indicator

OFF	no switch active
Red	Switch A1 active
Green	Switch A2 active
Orange	Switch A1 and A2 active

Specifications are subject to change without notice
Status: 27.11.2014
SAP: 88066